

# NEBRASKA STATE FIRE MARSHAL OFFICIAL INTERPRETATION



**Interpretation Number:** 00-07

**Date:** 31 October 2003

**Pamphlet Number:** Title 156, NAG

**Section(s):** 4.1.3 (9)

**Comments:**

Number of required accessible exits

**Question:** What is the requirement for the total number of accessible exits?

**Response:** For **new** construction the total number of required accessible exits is based on the total number of required exits for Life Safety. All the required exits shall be accessible.

For **existing** construction only if the exits are being modified, will the exit be required to be made accessible, to an extent that is feasible.

**Signature:** \_\_\_\_\_ **Date:** \_\_\_\_\_

**Title:** Dennis C. Hohbein, State of Nebraska Fire Marshal